



LANCASTER COUNTY FIRE CHIEFS ASSOCIATION, INC.

Apparatus Standards Checklist

Hose Unit

Date of Inspection: _____

_____ Optional: Verification of compliance with the National Fire Protection (NFPA) Standard (Std.) 1901 for Automotive Apparatus.

_____ Verification of the pump test in accordance with NFPA Std. 1911, Service Test of Pumps on Fire Department Apparatus.

Date: _____ Testing Authority: _____

Verification of Ground Ladder certification in accordance with NFPA Std. 1931, Design of and Design Verification Tests for Fire Department Ground Ladders.

Date: _____ Manufacturer: _____

List any Waivers: _____

_____ Minimum of 2,100 ft. of Large Diameter Hose (LDH).

_____ Minimum of 1,500 gpm pump.

_____ 1/4 inch NPT low pressure air fittings.

_____ 3 Prong, 20 AMP NEMA L5-20 R Electrical Connections.

NFPA 1901 Equipment

_____ Two wheel chocks, mounted in readily accessible locations, that meet or exceed the requirements of SAE J348, Standard for Wheel Chocks, for the wheel diameter on which the chocks are to be used

PASS: _____ FAIL: _____

Re-inspection Date: _____



LANCASTER COUNTY FIRE CHIEFS ASSOCIATION, INC.

Apparatus Standards Checklist

Hose Unit (Contd.)

Comments: _____

Inspector Signature: _____

Inspector Signature: _____