



LANCASTER COUNTY FIRE CHIEFS ASSOCIATION, INC.

Apparatus Standards Checklist

Tanker

Date of Inspection: _____

_____ Optional: Verification of compliance with the National Fire Protection (NFPA) Standard (Std.) 1901 for Automotive Apparatus.

_____ Verification of the pump test in accordance with NFPA Std. 1911, Service Test of Pumps on Fire Department Apparatus.

Date: _____ Testing Authority: _____

Verification of Ground Ladder certification in accordance with NFPA Std. 1931, Design of and Design Verification Tests for Fire Department Ground Ladders.

Date: _____ Manufacturer: _____

List any Waivers: _____

_____ Is the water capacity a minimum of 1,800 gallons?

Tank Capacity: _____

_____ Porta tank equal or greater than the size of the Tanker up to 4,000 gallons. (Optional)

_____ Siphon device or low-level strainer with siphoning capability.

_____ Direct tank fills with 3" standard storz coupling – minimum of (2).

_____ Rear dump – minimum of (1). May have side dumps.

_____ 1/4 inch NPT low pressure air fittings.

_____ 3 Prong, 20 AMP NEMA L5-20 R Electrical Connections.

NFPA 1901 Equipment

_____ If the apparatus is equipped with a pump, a minimum of 15 ft (4.6 m) of soft suction hose or 20 ft (6 m) of hard suction hose shall be carried.



LANCASTER COUNTY FIRE CHIEFS ASSOCIATION, INC.

Apparatus Standards Checklist

Tanker (Contd.)

_____ Where hard suction hose is provided, a suction strainer shall be furnished.

_____ Two wheel chocks, mounted in readily accessible locations, that meet or exceed the requirements of SAE J348, Standard for Wheel Chocks, for the wheel diameter on which the chocks are to be used

PASS: _____ FAIL: _____

Re-inspection Date: _____

Comments: _____

Inspector Signature: _____

Inspector Signature: _____